

कार्यालय नगर परिषद हनुमानगढ़-राजस्थान




वार्ड संख्या 34, गटनेर दुर्ग मार्ग, हनुमानगढ़- 335513
ई-मेल:-mch.hanumangarh@gmail.com,
दूरभाष:- 01552-222930, 223930

क्रमांक एफ:7 (भण्डार)/(गैराज)2024/764

दिनांक:-24/4/24

—: स्वच्छता प्रमाण-पत्र :-

प्रमाणित किया जाता है कि गुरु हरकिशन सीनियर सैकेण्डरी पब्लिक स्कूल, हनुमानगढ़ जंक्शन (पिनकोड-335512), राजस्थान का दिनांक 24.04.2024 को मेरे द्वारा निरीक्षण किया गया जिसमें स्वच्छता मानकों के अनुसार शौचालयों में सफाई व्यवस्था है एवं गीला-सूखा कचरा हेतु अलग-अलग कचरा पात्र (डस्टबिन) उपयोग में लिये जा रहे हैं।


मुख्य स्वच्छता निरीक्षक
नगरपरिषद हनुमानगढ़

Self Attested



Principal

Guru Harkrishan Sr.Sec. Public School
Hanumangarh Junction


Secretary

Guru Harkrishan Public School
& College Society, Hanumangarh



Office of the Junior Chemist
Public Health Engineering Department, Rajasthan
District Laboratory, Hanumangarh

Report of the Bacteriological Examination of Water

67 Date : 18/04/2024

To,
Principal,
Guru Harkrishan Sr.Sec.Public School,
Guru Harkrishan Sr.Sec.Public School.

District : HANUMANGARH



Sample Taker : Naresh Kumar


Reference No : 6314, Dated : 15/04/2024
Date of Receipt : 15/04/2024
Date of Exam : 15/04/2024

Sample No.	Date & Time of Collection	Village / Town / City	Source Name	Location	Residual Chlorine (in mg/L)	Total Coli Form Organism (MPN per 100 ml)	Remark (As per T-Coli Form)	Remark (Water)
96	15/04/2024 11:00:AM	Hanumangarh (M)	Tap	Guru Harkrishan Sr.Sec.Public Scho	Nil	Nil	Satisfactory	Potable

No.Lab./Tcty.(Bact)/2024-25/96


Junior Chemist
PHED Laboratory, Hanumangarh



Principal
Guru Harkrishan Sr.Sec. Public School
Hanumangarh Junction


Secretary
Guru Harkrishan Public School
& College Society, Hanumangarh

Office of the Junior Chemist
Public Health Engineering Department, Rajasthan
District Laboratory, Hanumangarh

Report of the Chemical Examination of Water

68

Date: 18/04/2024

Reference :- 6314 - Date: 18/04/2024

To:
Principal,
Guru Harkrishan Sr.Sec.Public School,
Guru Harkrishan Sr.Sec.Public School.

District - HANUMANGARH
Town - Hanumangarh (M)

Sample No.	Gram Panchayat	Village/ Town	Habitation	Source Name	Location	Collection Date	Date of Examination	pH	Acidity	Total Hardness	Calcium	Magnesium	Chloride	Nitrate	Fluoride	T.D.S.
57		Hanumangarh (M)		Tap	Guru Harkrishan Sr.Sec.Public School	18/04/2024	18/04/2024	7.0	70	90	20	0.76	30	3	0.02	220

P. Singh
Principal
Guru Harkrishan Sr.Sec. Public School
Hanumangarh Junction

Self Attested

S. Singh
Secretary
Guru Harkrishan Public School
& College Society, Hanumangarh

[Signature]
Junior Chemist
PHED Laboratory, District Laboratory

Note :- All Hardness except pH are in mg/l
Water is Potable (P) Unpotable (U)
T.D.S. Tech. (chem) /2024-25/57